

OFFICE OF THE CHIEF OFFICER  
NOTIFIED AREA AUTHORITY

Plot No. 619, AIA Community Centre,  
GIDC, Ankleshwar - 393 001  
Tel : (02826) 263091, 222487 Fax : 251750  
E-mail : nacank@yahoo.com

મુખ્ય અધિકારીશ્રીની કચેરી  
નિર્દિષ્ટ વિસ્તાર  
પ્લોટ નં. 619, સી.સી.સી. સમુદાય કેન્દ્ર,  
ગિડીસી, અંકલેશ્વર - ૩૯૩૦૦૧  
ટેલ : (૦૨૮૨૬) ૨૬૩૦૯૧, ૨૨૨૪૮૭ ફેક્સ : ૨૫૧૭૫૦

Ref. No. : N.T.A/JANKI 3663

Date : - -201  
10 NOV 2020

FIRE SAFETY CERTIFICATE

To,  
Shree Swaminarayan Gurukul Public School  
managed by Shree Swaminaraya Sevaniketan  
Plot No. 508, GIDC, Ankleshwar.

Sub: Inspection of Fire Protection Systems.

Ref. ; Your Request Letter Dtd. 04.11.2020.

This is to certify that our Fire Safety Officers have inspected the Fire Protection Systems & Equipments installed / provided in your premises on 07.11.2020.

The following Fire Fighting Equipments / Systems were found in the premises during the visit;

- Portable fire extinguishers at various locations.

It is suggested to take following measures to improve the Fire Protection System as per Fire Safety Norms;

- A pump of minimum 450 LPM with min. 3.5 kg./ cm<sup>2</sup> pressure (at highest point) connected with Water Tank of minimum 10000 ltrs. shall be provided at terrace.
- First Aid Hose reels connected with pump shall be provided at every floor.

This certificate does not confirm the adequacy of the Fire Protection system and facilities provided in the premises. The Fire Protection System & Equipment provided in the premises were found in good condition during the visit. However we are not responsible for any failure or nonperformance of any equipment / system during operation as far as statutory part is concerned.

The Fire Inspection Certificate has been issued on request, payment of necessary fees by recipient and on the basis of site inspection and verification of documents submitted with a condition to arrange for regular check-up and maintenance as per norms.

The Fire Inspection Certificate is valid for 12 months from the date of issue and subject to the next periodical Inspection after modification OR before expiry date, whichever is earlier.

F Spshtariya  
Principal  
Shree Swaminarayan

10/11/20